


filename : MT70-LED-T7-HE-CL.LDT
 meas. number : 2901
 luminaire number : MT70-LED-T7-HE-CL
 date / operator : 13-03-2019

**default lamp type(s)**

no of lamps	lamp type	luminaire lumens	input wattage
1	LED MODULE	4625 lm	30.1 W

dimensions

luminaire		luminous area	
length	: 2020 mm	length	: 1960 mm
width	: 75 mm	width	: 70 mm
height	: 75 mm	height	: 35 mm

coordinate system


no of planes	: 7	samples / plane	: 37
first c-plane	: 0.0 °	first gamma-angle	: 0.0 °
step angle	: 15.0 °	step angle	: 5.0 °
last c-plane	: 90.0 °	last gamma-angle	: 180.0 °
symmetrics : symmetry to C0 / C90			

performance

light output ratio : 100.0 %
 DFF : 99.3 %
 UFF : 0.7 %

classification


LiTG / DIN : A40
 UTE : 0.99D+0.01T 0.99E+0.01T
 CIE : 47 79 96 99 100
 BZ : 4 4 4 4 4 4 4 4 4
 Ambient Temperature : 25 degC
 Input Voltage : 240 V
 Circuit Watts : 30.1W
 Amps (running) : 0.133A
 V.A. : 32.02VA
 Power Factor : 0.94
 CCT : 3908K (measured): 4000K (declared)
 CRI (Ra) : 87
 S/P Ratio : 1.7
 Luminaire Lumens : 4625 LLm
 Output Current DC : 170 mA
 Output Voltage DC : 155V
 Output Power : 26.35W
 Luminaire Lm/circ.Watt : 154 LLm/circ.Watt
 Driver Efficiency : 87.5 %
 Driver Details : TRIDONIC LC 75W 100-400mA
 FLEX C 1P EXC 280000713



Measurements made are in absolute units. The luminaire is treated as if it was a lamp as it is not possible to measure each LED separately - hence an LOR of 100%

The Light output ratio in real terms would be less than 100%. If it was possible to compare real LED lumens with the total output from the luminaire we could obtain an actual LOR

This also means that the total lumens emitted from the LED's would be greater than the Luminaire Lumens measured. In reality the LED lumens would approximate to this value divided by the actual Light Output.



	C 0.0	C 15.0	C 30.0	C 45.0	C 60.0	C 75.0	C 90.0
0.0°	349.90	349.90	349.90	349.90	349.90	349.90	349.90
5.0°	343.30	343.30	343.40	344.80	346.20	347.30	348.40
10.0°	339.40	338.20	337.00	338.70	340.30	342.50	344.60
15.0°	329.10	328.80	328.60	329.50	330.50	333.40	336.40
20.0°	318.10	317.70	317.30	320.30	323.30	325.80	328.20
25.0°	306.30	307.10	308.00	308.10	308.30	312.60	316.80
30.0°	295.60	293.10	290.50	292.40	294.20	297.90	301.50
35.0°	277.10	276.70	276.30	275.30	274.40	280.10	285.70
40.0°	255.60	255.50	255.40	256.90	258.50	261.90	265.20
45.0°	233.50	232.00	230.60	233.00	235.40	239.20	242.90
50.0°	213.10	209.90	206.60	209.40	212.20	215.60	219.00
55.0°	178.40	180.70	183.00	183.50	184.10	186.60	189.10
60.0°	156.90	154.20	151.60	151.90	152.20	154.40	156.70
65.0°	129.50	127.90	126.30	124.10	121.90	122.10	122.20
70.0°	100.10	97.20	94.40	92.00	89.70	88.50	87.20
75.0°	65.70	65.30	65.00	64.70	64.40	57.90	51.40
80.0°	36.90	37.00	37.10	35.70	34.20	28.10	22.00
85.0°	16.80	15.90	15.00	14.50	13.90	10.20	6.40
90.0°	6.00	5.90	5.80	5.50	5.30	2.60	0.00
95.0°	3.80	3.80	3.80	3.80	3.80	1.90	0.00
100.0°	3.30	3.40	3.50	3.40	3.30	1.70	0.00
105.0°	3.10	3.20	3.20	3.10	3.00	1.50	0.00
110.0°	3.00	3.00	3.00	1.50	0.00	0.00	0.00
115.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
120.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
125.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
130.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
135.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
140.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
145.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
150.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
155.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
160.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
165.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
170.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
175.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
180.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	cd / klm						

glare rating according to UGR											
ρ-ceiling		70	70	50	50	30	70	70	50	50	30
ρ-walls		50	30	50	30	30	50	30	50	30	30
ρ-workplane		20	20	20	20	20	20	20	20	20	20
room dimensions X Y		viewed crosswise					viewed endwise				
2H	2H	19.3	20.8	19.6	21.0	21.3	20.4	22.0	20.7	22.2	22.4
	3H	20.0	21.1	20.2	21.3	21.5	21.2	22.3	21.4	22.5	22.7
	4H	20.4	21.5	20.7	21.7	21.9	21.7	22.8	21.9	23.0	23.2
	6H	20.6	21.7	21.0	21.9	22.2	21.9	22.9	22.2	23.2	23.4
	8H	20.7	21.8	21.1	22.0	22.3	22.0	23.0	22.3	23.3	23.5
	12H	20.8	21.8	21.1	22.1	22.4	22.0	23.0	22.3	23.3	23.6
4H	2H	19.4	20.5	19.7	20.7	20.9	20.3	21.4	20.6	21.6	21.8
	3H	20.9	22.0	21.3	22.2	22.5	21.9	23.0	22.3	23.2	23.5
	4H	21.6	22.6	21.9	22.9	23.2	22.6	23.6	23.0	23.9	24.2
	6H	21.7	22.5	22.0	22.8	23.1	22.7	23.5	23.1	23.8	24.2
	8H	21.8	22.6	22.2	22.9	23.3	22.8	23.6	23.2	23.9	24.3
	12H	22.0	22.7	22.4	23.1	23.5	23.0	23.8	23.4	24.1	24.6
8H	4H	21.6	22.4	22.0	22.8	23.1	22.6	23.4	23.0	23.7	24.1
	6H	22.3	23.0	22.8	23.4	23.9	23.3	24.0	23.7	24.4	24.8
	8H	22.5	23.2	23.0	23.7	24.2	23.5	24.2	24.0	24.6	25.1
	12H	22.5	23.1	23.0	23.6	24.1	23.4	24.0	23.9	24.5	25.0
12H	4H	21.8	22.6	22.3	23.0	23.4	22.8	23.5	23.2	23.9	24.3
	6H	22.4	23.1	22.9	23.6	24.1	23.4	24.1	23.9	24.5	25.0
	8H	22.5	23.1	23.0	23.5	24.0	23.4	24.0	23.9	24.5	25.0
variation of observer position											
S =	1.0H	+0.1/ -0.2				+0.1/ -0.1					
	1.5H	+0.3/ -0.5				+0.2/ -0.3					
	2.0H	+0.6/ -0.9				+0.8/ -0.9					
standard-table		BK04					BK04				
correction for luminaire		4.7					5.7				
correct glare indices for a total flux of 4625lm											




Table of intensities

gamma	C 0	C 90	C 180	C 270
45°	7421.1	11376.6	7421.1	11376.6
50°	7002.8	11245.8	7002.8	11245.8
55°	6116.9	10837.3	6116.9	10837.3
60°	5668.8	10247.7	5668.8	10247.7
65°	4984.7	9387.7	4984.7	9387.7
70°	4156.3	8192.6	4156.3	8192.6
75°	2985.7	6276.3	2985.7	6276.3
80°	1867.6	3878.1	1867.6	3878.1
85°	967.7	2055.8	967.7	2055.8

all values in cd/m²

utilization factors / TM5											
reflection			room index								
C	W	F	0.75	1.0	1.25	1.5	2.0	2.5	3.0	4.0	5.0
70	50	20	60	68	76	81	88	93	96	101	103
70	30	20	52	61	68	74	82	87	91	96	100
70	10	20	47	55	63	69	77	83	87	93	97
50	50	20	58	66	73	78	85	89	92	96	99
50	30	20	51	59	67	72	80	85	88	93	96
50	10	20	46	54	62	68	75	81	85	90	94
30	50	20	57	64	71	75	82	86	89	93	95
30	30	20	51	58	66	71	77	82	85	90	93
30	10	20	46	54	61	66	74	79	83	87	91
0	0	0	44	51	58	63	70	75	78	83	86
BZ-class			4	4	4	4	4	4	4	4	4
SHRnom : 1.50						SHRmax : 1.608					

